# COBB COUNTY DEPARTMENT OF TRANSPORTATION ENGINEERING DIVISION

Resurfacing 2012-2 Local Roads (South) Project No. E9020 December 13, 2011

#### ADDENDUM NO. 2

## **Proposals Received Until DECEMBER 15, 2011 – 12:00 Noon Local Time**

The following addendum hereby amends and/or modifies the Bid Documents and Contract Specifications as issued for this project. All bidders are subject to the provisions of this Addendum. **Bidders shall** acknowledge receipt of this addendum.

NOTE: Addenda, including plan holder lists, will be posted online at the following websites for Cobb Purchasing and Cobb DOT: <a href="http://purchasing.cobbcountyga.gov/bid-list.htm">http://purchasing.cobbcountyga.gov/bid-list.htm</a> and <a href="http://purchasing.cobbcountyga.gov/bid-list.htm">http://purchasing.cobbcountyga.gov/bid-list.htm</a> and <a href="http://purchasing.cobbcountyga.gov/bid-list.htm">http://purchasing.cobbcountyga.gov/bid-list.htm</a> and <a href="http://dot.cobbcountyga.gov/bid-rfp.htm">http://dot.cobbcountyga.gov/bid-rfp.htm</a>. Receipt of addenda must be acknowledged in the bid document. It is the bidder's ultimate responsibility to ensure that they have all <a href="https://applicable.gov/bid-state/">applicable</a> addenda prior to bid submittal and to utilize the latest bid schedule.

Contractor to pay special attention to the Cobb County Water System Details, provided with addendum.

#### I. QUESTIONS/ANSWERS

- Q. The only pay items for striping are for thermoplastic 24" and thermoplastic 8". In the past Cobb Co. has paid for any temporary striping (paint) that would be needed on the project. Is it safe to assume that the contractor will not be required to paint the 24" and 8" items before the thermoplastic is placed?
- A. Pre-mark existing with tape until permanent thermo markings can go in.
- Q. Black Bear Dr. and Fox Ln. both have existing side parking areas. Will these areas be edge milled and paved?
- A. Yes, those areas are in the right of way.
- Q. Pinecrest Rd. has an existing 4" or 5" solid yellow stripe for a centerline. Will this centerline be replaced after the road has been resurfaced. There is not a pay item to cover this item.
- A. At this time there is no intention to put back any centerline markings on a residential street. If it's decided to stripe later then the cost will be covered in Construction Allowance.

ADDENDUM No. 2 December 13, 2011 Resurfacing 2012-2 Local Roads (South) Project No. E9020 Page 2

> Michael S. Cates, P.E. Pre-Construction Engineer

### MSC/RJG/jan

cc:

Electronic copies:

John Flood, Cobb County Purchasing (w/hard copy)

Bob Galante, CCDOT Construction Ted Harris, CCDOT Operations

Russell Cooke, CCWS

Wade Kelly, CCDOT Construction See Alexander, CCDOT Construction

Jeff Neiswender, CCDOT Construction

Andy Rikard, CCDOT Utility Coordinator, Engineering

Denise Hatabian, CCDOT Construction Mike Lehner, CCDOT Construction Lynn Lambert, CCDOT Engineering

David Muller, CCDOT Utility Coordinator, Construction